
Serial Communication Cable
EV-SER-925 to Serial Port 1
Short Haul Modem
EV-SH-MOD
Central Computer
Hardwire Communications where Submaster is more than 100 feet from Central Computer.
Satellite Address 1-2
Satellite Address 1-1
To "In" Port of DX-HW
Continue to connect Controllers in a serial configuration, using EV-CAB-COMM Communications Cable.
Direct Burial 4-Conductor Communication Cable. EV-CAB-SH-COM
From "Out" Port of DX-HW
EV-CAB-COMM
Submaster Address 1-0
To "In" Port of DX-HW
EV-CAB-COMM (Maximum Cable Length is 5000 feet)
From "Out" Port of DX-HW
417-0025
DX-HW Communications Board inside Controller
Direct Burial 4-Conductor Communication Cable. EV-CAB-SH-COM
Short-Haul Modem Inside Controller EV-SHMOD
DC. Transformer Connects to 117 VAC at Controller
RAIN MASTER