EV-ETHER-CTRAL Ethernet Controller

CABLE EV-SER-925 To Computer

Central Computer

From EV-ETHER-CTRAL RJ-45 Port

Maximum Ethernet Cable Length is 300 Feet between each Node and the Hub

Customer Provided Base-10 Ethernet Hub or Switch

Satellite Address 1-1

Continue to connect Controllers in a serial configuration, using EV-CAB-COMM Communications Cable.

From "Out" Port of DX-HW

Submaster Address 1-0

EV-CAB-COMM (Maximum length between Controllers is 5000 feet)

To "In" Port of DX-HW

EV-CAB-COMM

From "Out" Port of DX-HW

CABLE 417-0025

EV-ETHER-SM Ethernet Controller

Direct Burial 4-Conductor Communication Cable EV-CAB-SH-COM (Maximum cable length is 5000 feet)

Short Haul Modem EV-SHMOD

DX-HW Communications Board inside Controller

417-0025

Direct Burial 4-Conductor Communication Cable. EV-CAB-SH-COM

Short-Haul Modem Inside Controller EV-SHMOD

DC Transformer Connects to 117 VAC at Controller

Irritrol®